



WALL / PARTITON NOTES

- 1. ALL EXTERIOR WALLS AND INTERIOR CORRIDOR WALLS ARE TO EXTEND TO THE UNDERSIDE OF THE METAL ROOF DECK(TYPICAL UNLESS SHOWN OTHERWISE). INTERIOR CORRIDOR WALLS SHALL BE SEALED WITH FIRE BARRIER CAULK TO PROVIDE A 1 HOUR FIRE RATING.
- 2. ALL CMU WALLS THAT ARE HATCHED (SOLID BLACK) ARE TO EXTEND TO 9'-4" A.F.F. AND ARE TO RECEIVE A METAL STUD ASSEMBLY, TO BE CONSTRUCTED ON TOP OF THE WALLS AND ARE TO EXTEND FROM 9'-4" A.F.F. TO THE UNDERSIDE OF THE METAL ROOF DECK ABOVE. THE METAL STUD ASSEMBLY IS TO CONSIST OF 3 8" METAL STUDS AT 16" O.C. WITH 3-1/2" FIBERGLASS BATT INSULATION WITH 1 LAYER 5/8" TYPE X GYP BOARD EACH SIDE. THE ASSEMBLY IS TO BE SEALED BETWEEN THE TOP OF THE WALL AND THE ROOF DECK TO PROVIDE A 1 HOUR FIRE RATING.
- 4. BRACE ALL CMU WALLS THAT TERMINATE AT 9'-4" A.F.F. WITH 20 GA. (MIN.) METAL STUDS AT 4'-0" O.C. (BRACED IN BOTH DIRECTIONS) BRACING TO EXTEND FROM TOP OF WALLS TO UNDERSIDE OF METAL DECKING. INSTALL BRACING AT AN 45 DEGREE ANGLE +/- 15 DEGREES.

SYMBOL LEGEND

- FIRE RATED WALL CAPS - INTERIOR CMU WALLS THAT TERMINATE AT 9'-4" A.F.F. WITH 3 8" METAL STUDS, 3-1/2" FIBERGLASS BATT INSULATION, AND 1 LAYER 5/8" TYPE X GYP BOARD EACH SIDE. THE ASSEMBLY IS TO BE SEALED BETWEEN THE TOP OF THE WALL AND THE ROOF DECK TO PROVIDE A 1 HOUR FIRE RATING. SEE WALL SECTION A2/A311
- FIRE RATED CMU WALLS - SEAL ASSEMBLY AT TOP OF CMU WALL AND AT THE UNDERSIDE OF ROOF DECK TO PROVIDE A 1 HOUR FIRE RATING.
- ACOUSTICAL WALL CAPS - INTERIOR CMU WALLS THAT TERMINATE AT 9'-4" A.F.F. WITH 3 8" METAL STUDS, 3-1/2" FIBERGLASS BATT INSULATION, AND 1 LAYER 5/8" GYP BOARD EACH SIDE. (FROM 9'-4" TO UNDERSIDE OF ROOF DECK) SEAL ASSEMBLY AT TOP OF CMU WALL AND AT THE UNDERSIDE OF METAL DECK. SEE WALL SECTION A2/A311



DAG ARCHITECTS INC.
40 S. PALAFOX ST. - STE 201
PENSACOLA, FLORIDA 32502
TELEPHONE: 850-429-0004 FAX: 850-429-9005
A-A-C000745

OWNERSHIP OF INSTRUMENTS OF SERVICE
ALL REPORTS, PLANS, SPECIFICATIONS, COMPUTER FILES, FIELD DATA, NOTES AND OTHER DOCUMENTS AND INSTRUMENTS PREPARED BY THE CONSULTANT AS INSTRUMENTS OF SERVICE SHALL REMAIN THE PROPERTY OF THE CONSULTANT. THE CONSULTANT SHALL RETAIN ALL COMMON LAW, STATUTORY AND OTHER RESERVED RIGHTS, INCLUDING THE COPYRIGHT THERE TO.

CONSTRUCTION
DOCUMENTS
(PHASE III)

MILTON HIGH SCHOOL
Science Lab Addition

5/1/13

PATRICK L. BALLASCH, AIA
AR 00017640

Revision		
Date:	No.	Description:
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-
-	-	-

Drawn By: WSB
Checked By: OEG

Date: 05-01-13

Project No.: 12035

Drawing Title:

FLOOR PLAN

Drawing No.: A101

